




Issue date: 22-06-2022 Expiry date: 31-12-2023 Page 1 of 5

Fire Door Hardware Requirements

SIDE HUNG (HINGED) DOORSETS

Following are the hardware requirements for Pyropanel hinged fire doorsets for various configurations.

Note: Hardware installed on fire doors needs to be approved for use on that specific door type. Also fire doors must be self-closing & self-latching. Please check proposed hardware with your nearest Pyropanel distributor.



SINGLE LEAF HINGED DOORS (A) Standard hardware

- (1) Door closer
- (2) Latching device
- (3) Hinges

ADDITIONAL OPTIONAL HARDWARE

- Electric strike or bolts
- Door seals
- Door viewers
- Hold open devices (Electrically controlled)
- Reed switches
- Kick plates
- Door edge protectors
- Power transfer devices
- Panic exit devices

ASSA ABLOY Australia Pty Ltd

235 Huntingdale Rd, Oakleigh, Vic 3166

Ph: (03) 9837 8500

Email: sales@pyropanel.com.au Web: www.pyropanel.com.au

Distributed by:

Solwest Doors





Issue date: 22-06-2022 Expiry date: 31-12-2023 Page 2 of 5

Fire Door Hardware Requirements

SIDE HUNG (HINGED) DOORSETS

Following are the hardware requirements for Pyropanel hinged fire doorsets for various configurations.

Note: Hardware installed on fire doors needs to be approved for use on that specific door type. Also fire doors must be self-closing & self-latching. Please check proposed hardware with your nearest Pyropanel distributor.



PAIR LEAF HINGED DOORS (B) Standard hardware

- (1) Door closers
- (2) Latching devices (for active leaf and non-active leaf)
- (3) Hinges
- (4) Sequence selector (if overlapping meeting stile astragals)
- (5) Meeting stiles/astragals (refer tech-sheet ACC-08)

ADDITIONAL OPTIONAL HARDWARE

- Electric strike or bolts
- Door seals
- Door viewers
- Hold open devices (Electrically controlled)
- Reed switches
- Kick plates
- Door edge protectors
- Power transfer devices
- Panic exit devices

ASSA ABLOY Australia Pty Ltd

235 Huntingdale Rd, Oakleigh, Vic 3166

Ph: (03) 9837 8500

Email: **sales@pyropanel.com.au**Web: **www.pyropanel.com.au**

Distributed by:

Solwest Doors






Issue date: 22-06-2022 Expiry date: 31-12-2023 Page 3 of 5

Fire Door Hardware Requirements

SIDE HUNG (HINGED) DOORSETS

Following are the hardware requirements for Pyropanel hinged fire doorsets for various configurations.

Note: Hardware installed on fire doors needs to be approved for use on that specific door type. Also fire doors must be self-closing & self-latching. Please check proposed hardware with your nearest Pyropanel distributor.



PAIR LEAF HINGED DOORS (C) - TOP LATCHING ONLY Standard hardware

- (1) Door closers
- (2) Latching devices (Pyropanel Roller Latch at the head of both door leaves)
- Hinges
- (4) Sequence selector (if overlapping meeting stile astragals)
- (5) J-section or Bullnose Meeting stiles/astragals (refer tech-sheet ACC-08)
- (6) Push and pull plate furniture

ADDITIONAL OPTIONAL HARDWARE

- Electric bolts
- Door seals
- Door viewers
- Hold open devices (Electrically controlled)
- Reed switches
- Kick plates
- Door edge protectors
- Power transfer devices
- Panic exit devices

ASSA ABLOY Australia Pty Ltd

235 Huntingdale Rd, Oakleigh, Vic 3166

Ph: (03) 9837 8500

Email: **sales@pyropanel.com.au**Web: **www.pyropanel.com.au**

Distributed by:

Solwest Doors






Issue date: 22-06-2022 Expiry date: 31-12-2023 Page 4 of 5

Fire Door Hardware Requirements

DOUBLE-ACTING (PIVOT) DOORSETS

Following are the hardware requirements for Pyropanel Double Acting (Pivot) fire doorsets for various configurations.

Note: Hardware installed on fire doors needs to be approved for use on that specific door type. Also fire doors must be self-closing & self-latching. Please check proposed hardware with your nearest Pyropanel distributor.



SINGLE LEAF DOUBLE ACTING (PIVOT) DOORS (D)

Standard hardware

- (1) Door closer (Transom or Floor Spring)
- (2) Latching device (Pyropanel Roller Latch)
- (3) Push/pull plate furniture
- (4) Bullnose Meeting stile/astrgal (refer tech-sheet ACC-08)

ADDITIONAL OPTIONAL HARDWARE

- Door viewers
- Kick plates
- Electromechanical locks

ASSA ABLOY Australia Pty Ltd

235 Huntingdale Rd, Oakleigh, Vic 3166

Ph: (03) 9837 8500

Email: sales@pyropanel.com.au Web: www.pyropanel.com.au

Distributed by:

Solwest Doors








Issue date: 22-06-2022 Expiry date: 31-12-2023 Page 5 of 5

Fire Door Hardware Requirements

DOUBLE-ACTING (PIVOT) DOORSETS DESCRIPTION

Following are the hardware requirements for Pyropanel Double Acting (Pivot) fire doorsets for various configurations.

Note: Hardware installed on fire doors needs to be approved for use on that specific door type. Also fire doors must be self-closing & self-latching. Please check proposed hardware with your nearest Pyropanel distributor.



DOUBLE LEAF DOUBLE ACTING PIVOT DOORS (E)

Standard hardware

- (1) Door closer (Transom or Floor Springs)
- (2) Latching device (Pyropanel Roller Latch)
- (3) Push plate furniture
- (4) Bullnose Meeting stile/astrgal (refer tech-sheet ACC-08)

ADDITIONAL OPTIONAL HARDWARE

- Door viewers
- Kick plates
- Electromechanical locks
- Pull handles

ASSA ABLOY Australia Pty Ltd

235 Huntingdale Rd, Oakleigh, Vic 3166

Ph: **(03) 9837 8500**

Email: sales@pyropanel.com.au Web: www.pyropanel.com.au

Distributed by:

Solwest Doors

